

CROSS COUNTY QUORUM COURT

APPROPRIATION ORDINANCE NO. _____

OFFICIAL: DONNIE SANDERS
SPONSOR:

BE IT ENACTED BY THE QUORUM COURT OF THE COUNTY OF CROSS, STATE OF ARKANSAS, AN ORDINANCE TO BE ENTITLED:

AN ORDINANCE TO APPROVE THE SPENDING FROM UNAPPROPRIATED AMERICAN RELIEF FUND IN AN AMOUNT NOT TO EXCEED \$144,212.00 TO THE CITY OF PARKIN;

WHEREAS: IT IS NECESSARY TO APPROVE THE SPENDING IN AN AMOUNT NOT TO EXCEED \$144,212.00 FOR A NEW GENERATOR TO POWER THE WATER SYSTEM DURING POWER OUTAGES;

WHEREAS: IT IS NECESSARY TO APPROVE THE SPENDING FROM UNAPPROPRIATED AMERICAN RELIEF FUND IN AN AMOUNT NOT TO EXCEED \$144,212.00 FOR A NEW GENERATOR TO POWER THE WATER SYSTEM DURING OUTAGES TO ELIMINATE FAILURES OF THE SYSTEM & CONTINUE SERVICE TO THE CITIZENS OF PARKIN;

WHEREAS: THIS COURT IS OF THE OPINION THIS APPROPRIATION IS FAIR AND REASONABLE.

NOW, THEREFORE, BE IT ORDAINED BY THE QUORUM COURT OF CROSS COUNTY, ARKANSAS.

PASSED AND APPROVED THIS _____.

DATE

ATTEST:

MELANIE WINKLER
COUNTY CLERK

DONNIE SANDERS
COUNTY JUDGE



QUOTE

Genflow Inc.

P.O. BOX 218, Wynne, AR 72396

Date: 9/16/2022
Customer ID: Mayor Patterson

To: City of Parkin

Salesperson	Job	Payment Terms	Column1
Rodney	Generator		upon receipt

Item #	Column1	Unit Price	Line Total
1.00	Kohler generator to be installed		\$ 198,712.00
	model #SDG1235-BE		
	72KW @ 120/240V, 10		
	100KW @ 120/208V, 30		
	100KW @ 277/480V, 30		
	Diesel fueled engine, 1800 RPM, Tier 4		
	Final EPA certified for nonroad app.		
	EPA certified for Prime Power app.		
	Operating on diesel fuel @ 100% load		
	8.1 gal. fuel per hr. 168 gallon tank.		
	400A Main, 3 Pole, Square D, 100%		
	rated with Electronic LSI trip. Sound		
	attenuated and weather protective,		
	Steel construction, (71dBA) Critical		
	grade, internally mounted within encl.		
	3-position, lockable, voltage sel.		
	Switch		
	wired for 120/240 V, 10, 120/208V 30,		
	277/480V 30. Cold weather pkg.		
	Dual-axle trailer with electric brake		
	system and spare tire, 2 & 5/16 ball		
	hitch, front and rear stabilizer jacks.		
		Subtotal	
		Sales Tax	
		Total	198,712.00

Make all checks payable to

Thank you for your business!

P.O. Box 218 Wynne, Ar. 72396 870-734-0050



QUOTE

Genflow Inc.

P.O. BOX 218, Wynne, AR 72386

Date: 9/16/2022
CUSTOMER ID: Blayor Patterson

To: City of Parkin

Salesperson	Job	Payment Terms	Comments
Kodney	Generator		upon receipt

Item #	Column 1	Unit Price	Line Total
1.00	200RE0ZJP -200KW 120/240V,30, with 4UAB alternator, Diesel fueled engine, 1800 RPM, EPA Certified for Emergency Standby Operation, 400 Gallon, UL 142 listed subbase with secondary containment, Full load run time 25.1 hr, 600A main, 3pole, 80.0 100% rated with Electronic LSI Trip Kohler APM 402 Digital Control Panel, meets NFPA-110 Level 1. Run relay 2 bus out module, NFPA-110 level 1, UL200, Sound Attenuated and weather protective, Steel construction, 73.7dBA Critical grade, Internally mounted with enclosure. Monitor 1800 watt, BA float/ equalize type (120VAC 10 power req. from a utility source), 1 Year, 2000hour Comprehensive warranty. Acut Transfer switch K65-AFYC- 0800S 600Amp @ 120/240V 10 with 3 pole		\$ 144,212.00
Subtotal			
Sales Tax			
Total			144,212.00

Make all checks payable to

Thank you for your business!

P.O. Box 218 Wynne, Ar. 72386 870-734-6866